

**PERFORMA FOR THE SAFETY CERTIFICATE OF SCHOOL BUILDING
(PART-I)**

(To be filled by the head of the School/Institute)

- | | | |
|-----|--|--|
| 1. | Name of School | DAWA RINJUE SCHOOL |
| 2. | Location | LALDHANG, VIKASNAGAR, DEHRADUN |
| 3. | Plot Area | 10,100 sqmt. |
| 4. | Plinth Area | 744 sqmt. |
| 5. | Number of Storey | 2 |
| 6. | Area of Constructed part of the building | |
| 7. | If the building is constructed under the Supervision of Qualified Engineer, the following details may be given:- | |
| | a) Name of Engineer with Qualification | RK Nautiyal, M Tech |
| | b) Address of Engineer | Phase II Vasant Vihar Dehradun |
| | c) If Structural Drawing used in construction. If available? | Yes |
| | d) Name and Address of Architect with Qualification | Pragati Consultant
4/10 Rajpur Road D.Dun |
| 8. | Whether the building has constructed for the purpose of: | |
| | a) School | School |
| | b) Residential Purpose and use of School | |
| 9. | Material used for Roofs | |
| | a) RCC Slab | RCC Slab |
| | b) RS Joists & Battons | |
| | c) Wooden Joints & Bottom | |
| 10. | Material used for Walls | |
| | a) Mud Mortar | |
| | b) Cement Mortar | Cement Mortar |
| | c) Lime Mortar | |
| 11. | Flooring | |
| | a) Conglomerate | |
| | b) Terrace | Terrace |
| | c) Brick Paving | |
| 12. | A detailed drawing indicating the doors along with windows and location fitting and windows is attached | |
| 13. | For Fire Safety | |
| | a) Whether the width of staircase is 1.5 mtr | Yes |
| | b) Whether portable fire extinguisher exists | Yes |
| | c) Whether School Building is free from inflammable & Toxic material. | Yes |
| | d) Whether cooking food is done at a safe place | Yes |
| | e) Whether and Thatch or combustible material has been used | No |

14. Requirement for Fire Protection Arrangements under NB- Part IV
(For Building height less than 15 meter)
- | | |
|---|-----|
| a) Whether Hose Reel Provided | Yes |
| b) Whether dome corner provided | Yes |
| c) Whether Automatic Sprinkler Provided | Yes |
| d) Whether underground static water storage tank of capacity 50000L (if covered area exceeds 1500 Sq.Mt.) | |
| e) Whether overhead tank of capacity 10000L | Yes |
| f) Whether one electric and one diesel pump of 3kg/cc Pressure of capacity 1620 LPM, one electric pump of Capacity 190 LPM exist near underground static tank | Yes |


President
D.R. School Society
Dehradun Road, Herbertpur
Distt. D.Dun (U.K.)

Signature of the Head of School/Institute

PART-II
(To be filled by the PWD department)

- a) I have visited the above mentioned school on date 22/03/2026 and have visually inspected it from all angles of safety and find it fit for normal use as school building.
- b) In case any addition / alteration or expansion and modifications to this building is to be carried out, the same be carried out under the supervision of qualified engineer and this certificate may be re- obtained after completion from the undersigned.
- c) In case the building safety is affected by flood or if there is settlement of walls/ Foundation or sagging in roofs etc immediate inspection of the undersigned be arranged to check the stability of the building.
- d) This building can be safely occupied for normal use up to (indicate which it can be used) one year.


सहायक अभियन्ता
अस्थाई खण्ड, लो0नि0वि0
सहिया, देहरादून